

# Attestation

## BREEAM International

On 2 February 2021, Eurofins Product Testing A/S received a sample of a wood based panel with the product name:

**Viroc Grey 12 mm**

supplied by

**INVESTWOOD SA**

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (See test report no.392-2021-00057301).

**Evaluation of the emission results according to the basic level emission criteria (table 17) of: BREEAM Int.: Hea 02 Indoor air quality:**

---

- Carcinogenic substances were not detectable after 28 days ( $< 0.001 \text{ mg/m}^3$ )
- The sum of VOC ("TVOC") after 28 days was below the limit of  $1.0 \text{ mg/m}^3$
- Formaldehyde after 28 days was below the limit of  $0.06 \text{ mg/m}^3$


---

**The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).**

19 March 2021



Rasmus Verdier  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry